

Daniel Murray

From: Greg Brand <GBrand@sjbhd.org>
Sent: Wednesday, October 22, 2014 2:56 PM
To: Victoria Schmitt; Daniel Murray
Cc: molson@rr-eng.com; wayne dale (sundale@yahoo.com); swlsinc@frontier.net; Chad Engelhardt; Wanda Humphrey; Greg Brand
Subject: FW: GCC Energy OSWS Permit #2007-344 and OSWS Permit #2007-345
Attachments: GCC Sanitary Demands 10-9-14.pdf; GCC Site Personnel and San Facilities 10.9.14.xlsx; GCC Energy - Projected water usage_August 2014.pdf

Categories: printed, printed attachment only

To: Victoria Schmitt, P.E.
La Plata County Planning Department

Re: GCC Energy – King II Coal Mine
CR 120, Hesperus, La Plata County Colorado
OSWS Permit #2007-344 and OSWS Permit #2007-345

San Juan Basin Health Department (“SJBHD”) has reviewed all of the attached documents as they relate to:
- SJBHD On-Site Wastewater System Permit #2007-344 and OSWS Permit #2007-345

SJBHD accepts the projected water usage contained in the letter from Mr. Wayne Dale, P.E. (Stoner Engineering – Cortez, CO) dated August 28, 2014.

Therefore, at this time, San Juan Basin Health Department has no concerns with GCC’s proposal to have a maximum of 165 employees.

San Juan Basin Health Department respectfully requests that La Plata County Planning Department consider including the following conditions of approval:

1. GCC Energy shall install appropriate water usage flow meter(s) on the main shower/locker/office and on the scale facility to measure/record the wastewater flowing into the permitted On-site Wastewater Systems.
2. GCC Energy shall appropriately document water usage from all water usage flow meters on a minimum frequency of once per week.
3. GCC Energy shall maintain all water usage flow meter documentation for a minimum of 10 years.
4. GCC Energy shall provide water usage flow meter documentation to La Plata County and/or San Juan Basin Health Department upon written request by La Plata County or SJBHD.

Please feel free to contact me if you have any questions, comments, or concerns.

Thank you

Gregory N. Brand, P.E.
Environmental Health Director
San Juan Basin Health Department
281 Sawyer Drive, Durango, CO 81303
Desk phone = (970) 335-2054
Main phone = (970) 247-5702
Email = gbrand@sjbhd.org

From: Victoria Schmitt [<mailto:Victoria.Schmitt@co.laplata.co.us>]
Sent: Thursday, October 09, 2014 5:38 PM
To: Chad Engelhardt; Greg Brand
Cc: Daniel Murray; Mike Olson (molson@rr-eng.com); South West Land Services; Wayne Dale
Subject: GCC OSWS

Chad and Greg,

Thank you for the meeting today. As discussed, since the updated SJBH permit addresses 75 employees while the County's files indicate the GCC operation intends 165 employees overall, ~ 100 employees on higher-demand days, and 87 employees averaged over the month, the County would like to assure the project we are considering does not exceed that which SJBH has permitted.

The attached spreadsheet and supporting documents summarize the personnel and sanitary facilities associated with the project based on applicant reporting. The County would like to confirm that SJBH has no concerns with these uses being permitted dependent on SJBH permits 2007-344 and 2007-345.

Thank you again.

Victoria Schmitt, PE
La Plata County Planning
970.382.6438
victoria.schmitt@co.laplata.co.us